

12-13-23

ADDENDUM #1
to the Drawings and Specifications for the
HVAC UNIT REPLACEMENT
Scenic Regional Library, St. Clair & Warrenton Branches

Scope of Work:

Add Alternate Bid #1:

Provide new add alternate bid for the following: **Replacement of existing split system mechanical air handlers & condensers (2 Each), and thermostats (if required) at the Warrenton Branch.** Min IECC SEER rating of 17 or higher. Provide all service and utility connections. Provide all required transitions and fittings for a complete installation.

Condensers are located on the Northwest side of the building West of the entrance. One air handler is in the Janitor's Closet near the front desk. The second air handler is in the Storage Room behind the front desk.

See attached images and revised Bid Form.

END of ADDENDUM

BID FORM

In response to the Invitation for Bids for HVAC Unit Replacement for Scenic Regional Library and in accordance with the Instructions to Bidders and other Bidding Documents, the undersigned Bidder declares that he has had an opportunity to examine the site of the Work and has carefully examined the Contract Documents therefore, including the Addenda identified below, and on the basis thereof, and being fully familiar with the local conditions affecting the Work, and upon written notice of award of contract, acknowledges and agrees to provide all labor, material, equipment, tools, management and supervision, safety and technical services, insurance, bonds and incidentals necessary or required for the faithful performance of the Contract Work in accordance with the above-referenced documents in a safe, timely and workmanlike manner.

Company name and address

Representative_____

Phone Number_____

Email_____

Commercial References including phone number

1. _____

2. _____

3. _____

Pricing

Branch Location	Cost by Location
St. Clair	\$
Warrenton	\$
Alternate Bid #1	\$
Total Cost	\$

Acknowledgements

Bidder understands that Owner reserves the right to reject any and all bids and to waive any informality in the bidding.

The Bidder agrees that this Bid shall be valid and may not be withdrawn for a period of ninety (90) days after the scheduled closing time for receiving bids.

Within ten (10) working days after receipt of written notice of award of contract, Bidder will execute and deliver to the Library District the formal Library-Contractor Agreement included in the Bid Package.

(Signature)

(Print Name)

(Company Name)

End of Bid Form





SERIAL 1701E02896

PROD 38CKC036---511--

MODEL 38CKC036510

PISTON ID 70 OD N/A

FACTORY CHARGED

R-22

5.00

LBS

2.27

INDOOR TXV SUBCOOLING

18

POWER SUPPLY

208/230

VOLTS

3

PH

60

HZ

PERMISSIBLE VOLTAGE AT UNIT

253

MAX

187

MIN

SUITABLE FOR OUTDOOR USE

COMPRESSOR

VOLTS AC

208/230

3

PH

60

HZ

10.0

RLA

70.0

LRA

FAN MOTOR

VOLTS AC

208/230

HP

1/5

FLA

1.4

1

PH

60

HZ

DESIGN/TEST PRESSURE GAGE

HI

PSI

300

KPa

2068

LO

PSI

150

KPa

1034

MINIMUM CIRCUIT AMPS

13.9

MAX FUSE 20

MAX CKT - BKR (")

20

* HACR TYPE RECOMMENDED

LISTED SECTION
OF CENTRAL COOLING
AIR CONDITIONER
3R28



VERIFIED
FOR ENERGY
PERFORMANCE



RENDMENT
ENERGETIQUE
VERIFIE



CERTIFICATION APPLIES ONLY WHEN THE COMPLETED
SYSTEM IS LISTED WITH ARI

Carrier Corporation
7310 West Morris St.
Indianapolis, IN 46231

324050-4224

SERIAL

1401E20382

PROD

38CK0036---S11--

MODEL

38CKC036510

PISTON

ID 70 100 N/A

FACTORY CHARGED

R-22

5.00 LBS

2.27 kg

INDOOR TVV SUBCOOLING

18 F

POWER SUPPLY

208/230

VOLTS

3

PH

60 HZ

PERMISSIBLE VOLTAGE AT UNIT

253

MAX

187 MIN

SUITABLE FOR OUTDOOR USE

COMPRESSOR

VOLTS AC

208/230

3

PH

60 HZ

10.0

RLA

70.0 LRA

FAN MOTOR

VOLTS AC

208/230

HP

1/5

FLA

1.4

1

PH

60 HZ

DESIGN/TEST PRESSURE GAUGE

HI PSI 300

kPa

2068

LO PSI 150

kPa

1034

MINIMUM CIRCUIT AMPS


13.9

MAX FUSE 20

MAX CWT - BKR (°)

20

* NACH TYPE RECOMMENDED

LISTED SECTION
OF CENTRAL COOLING
AIR CONDITIONER
3824VERIFIED
FOR ENERGY
PERFORMANCERECOMMEND
ENERGETIQUE
VERIFIERCERTIFICATION APPLIES ONLY WHEN THE COMPLETED
SYSTEM IS LISTED WITH ARICarrier Corporation
2010 Wacker Drive SE
Indianapolis, IN 46221

324050-4224